



Testing. Advising. Assuring.

EWFA CERTIFICATE OF ASSESSMENT	CERTIFICATE No : SFC 28750-00	Page 1 of 1
---------------------------------------	--------------------------------------	--------------------

Report Sponsor	Certificate Issue Date	Product Name
Projex Group Pty Ltd 2/1 Military Road Matraville NSW 2036 Australia	03/09/2013	Model "T" Link-Seal® modular seal system

Assessment Report Reference	Referenced Standard	Report Issue Date	Report Validity Date
EWFA 28750-00	AS1530.4-2005 AS4072.1-2005	03/09/2013	30/09/2018

Introduction



The element of construction described below was assessed by this laboratory on behalf of the report sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report(s) or Regulatory Information Reports for a complete description of the assessed construction.

Description of Assessed Construction and Performance

Assessed Construction	FRL
<p>The assessed construction comprises a Ø 275mm x 10mm thick steel pipe penetrated through a 200mm thick precast cement block. Silicone (Grey) rubber Model "T" Link-Seal® modular seal system is installed surrounding the steel pipe perimeter and is flushed along the unexposed surface of precast cement block.</p> <p>Refer to the referenced assessment report for a complete description of the assessed construction.</p>	-120/-

Conditions/Validity

- THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.
- Reference should be made to the relevant test report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The assessment report or short form assessment report does not provide an endorsement by Exova Warringtonfire Aus Pty Ltd of the performance of the actual products supplied. It is intended to provide a brief outline of the above referenced assessment reports and not to replace them.
- The conclusions in this certificate of assessment relate to the configurations as detailed, and should not be applied to any other configuration. The conclusions expressed in this document assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- Full copies of the assessment and relevant test reports may be obtained from the sponsor.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	Suite 2002a, Level 20, 44 Market Street, Sydney NSW 2000, Australia	
Phone / Fax	+61 (0)2 8270 7600 / +61 (0)2 9299 6076	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By:  S. Hu	Reviewed By:  K. G. Nicholls